



ICC-ES Listing Report

ESL-1054

Reissued March 2024

This listing is subject to renewal March 2025.

CSI: DIVISION: 06 00 00—WOOD, PLASTICS AND COMPOSITES
Section: 06 50 00—Structural Plastics

Product Certification System:

The ICC-ES product-certification system includes evaluating reports of tests of standard manufactured product, prepared by accredited testing laboratories and provided by the listee, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the listee's quality system.

Products: NEWTECHWOOD CLADDING BOARDS

Listee: NEWTECHWOOD AMERICA, INC.

Evaluation: The NewTechWood Cladding boards were evaluated when tested at a nominal thickness of ½ inch (12.7 mm) to the following standards:

- ASTM E84-16 and ASTM E84-2013a, Standard Test Method for Surface Burning Characteristics of Building Materials, ASTM International.

Findings: The NewTechWood Cladding boards have a flame spread index of 200 or less and a smoke-developed index of 450 or less, when tested in accordance with ASTM E84, and is limited to exterior use, as referenced in the applicable sections of the following code editions:

- 2018 *International Building Code*®
Applicable Section: 803.1.2
- 2015 *International Building Code*®
Applicable Section: 803.1.1
- 2018 and 2015 *International Residential Code*®
Applicable Section: R302.9

Identification:

1. The NewTechWood Cladding boards described in this listing report is identified by a label on the packaging, bearing the NewTechWood America, Inc. name and address, the product name, the listing report number (ESL-1054), and when applicable, the ICC-ES Listing Mark.
2. The report holder's contact information is the following:

NEWTECHWOOD AMERICA, INC.
15912 INTERNATIONAL PLAZA DRIVE
HOUSTON, TEXAS 77032
(281) 570-6450
www.newtechwood.com

Installation: The product must be installed in accordance with the NewTechWood America, Inc.'s published installation instructions and applicable codes.

Conditions of listing:

1. The listing report addresses only conformance with the standard and code sections noted above.
2. Approval of the product's use is the sole responsibility of the local code official.
3. The listing report applies only to the products tested and as submitted for review by ICC-ES.
4. The products described in this listing report is produced under a quality control program with inspections by ICC-ES.